



**TOWN OF GROTON  
Board of Health  
173 Main Street  
Groton, Massachusetts 01450**

**MEETING MINUTES  
July 6, 2015**

Board of Health Members Present:

Jason Weber, Member  
Susan Horowitz, Member

Others Present:

Ira Grossman, Health Agent  
Regina Beausoleil, Interdepartmental Assistant

Not present:

Robert Fleischer, Chairman

Meeting Called to Order:

Member Weber called the meeting to order at 6:00 pm in the Town Hall.

37 West Main Street – Doug and Kate Smith, Soilsmith Designs

Mr. Smith was before the Board to present an SDS Variance request for a Presby Sysytem. He stated he wasn't sure the current system was even on the property. Member Horowitz asked where the system for Squannacook Hall was located. Mr. Grossman stated it was located in the front. He also stated there were currently components that cannot be driven over, noting that they should change the tank rating to be H20 rated in case the Squannacook access agreement does not work out.

***Member Horowitz made a motion to approve the variance as requested and would recommend an H20 rated tank be used. Member Weber seconded the motion and the vote was unanimous.***

***Member Horowitz made a motion to adjourn the meeting at 6:10PM. Member Weber seconded the motion and the vote was unanimous.***

Respectfully submitted,

Regina Beausoleil

**APPROVED: May 16, 2016**

---