

ADA Transition Plan

Action Item	Regulation – ADA - AAB	Person Responsible	Cost Estimate	Expected Completion Date
<p>1. Goal is to relocate trash bin obstructing accessible sink.</p>	<p>ADA, 2010 Amendments, priority two, Access to goods and services, in section 2.78 "There shall be clear floor space at least 30 inches wide..."</p>	<p>ADA Coordinator/ Town Manager</p>	<p>Labor 1/2 Hour <b>Total</b> \$60.00</p>	<p>12/31/19</p>
<p>2. Goal is to install a soap dispenser in one of the 2<sup>nd</sup> Floor Unisex Restrooms.</p>	<p>MA AAB 521 CMR 30.12 state "Towel dispensers, drying devices, or other types of devices and dispensers shall have at least one of each device mounted within the zone of reach. At least one of each device shall be located within reach of a person using the accessible sink and shall comply with 521 CMR 39.5, Operation."</p>	<p>ADA Coordinator/ Town Manager</p>	<p>Dispenser \$12.00 Labor 1/2 Hour <b>Total</b> \$72.00</p>	<p>12/31/19</p>

--	--	--	--	--