

**ADA Transition Plan**

Action Item	Regulation – ADA - AAB	Person Responsible	Cost Estimate	Expected Completion Date
<p>1. The goal is to install a HP "Van Accessible" parking sign at the HP accessible parking space.</p>	<p>ADA Section 4.6.4 "Space shall have an additional sign "Van Accessible" mounted below the symbol of accessibility."</p>	<p>ADA Coordinator/ Town Manager</p>	<p>Sign \$85.00 Labor 1 Hour <b>Total</b> \$205.00</p>	<p>12/31/19</p>
<p>2. The goal is to install accessible coat hooks in both the Men's and Women's restrooms.</p>	<p>MA AAB states "Coat hooks shall be 54 inches high."</p>	<p>ADA Coordinator/ Town Manager</p>	<p>2 Coat hooks \$10.00 Labor \$120.00 <b>Total</b> \$130.00</p>	<p>12/31/19</p>
<p>3. The goal is to install grab bars in the shower.</p>	<p>ADA 2010 standards, Section 608.3.1 Transfer Type Shower Compartments "In transfer type compartments, grab bars shall be provided across the control wall and back wall to a point 18 inches (455 mm) from the control wall."</p>	<p>ADA Coordinator/ Town Manager</p>	<p>\$113. + 111. 111. 335.00 + <u>480.00</u> Labor <b>Total</b> \$815.00</p>	<p>12/31/19</p>
<p>4. The goal is to install an A/V alarm in the small conference room.</p>	<p>ADAAG requirements, Section 4.28 "Visual signal appliances shall be provided in restrooms as well as any other general usage areas."</p>	<p>ADA Coordinator/ Town Manager</p>	<p>\$1560. Est. for wiring, and labor</p>	<p>12/31/19</p>

<p>5. The goal is to install knurled handles on the Janitor and Storage closets.</p>	<p>AAB Section 26.11.4 states "All Doors opening into hazardous areas shall have hardware, which is knurled or roughened."</p>	<p>ADA Coordinator/ Town Manager</p>	<p>Handles \$95.00 each Labor 1 hour <b>Total</b> \$310.00</p>	<p>12/31/19</p>
--	--	--	--	-----------------

**Site – Groton Electric Light Department**

**Address – 23 Station Avenue Groton, MA**

**January 3, 2019**

--	--	--	--	--