

**COST OF ADA TRANSITION PLAN**  
**for Department Head Review**  
**January 17, 2019**

Item	Building/Item	Installation Deadline	Estimated Item Cost	Estimated Total Cost
	<b>CENTER FIRE STATION</b>			
1	Relocate trash bin obstructing accessible sink.	31-Dec-19	\$60.00	
2	Install a soap dispenser in one of the 2 <sup>nd</sup> Floor Unisex Restrooms.	31-Dec-19	\$72.00	
				<b>\$132.00</b>
	<b>GROTON COUNTRY CLUB</b>			
1	Relocate dumpsters that obstruct HP parking.	31-Dec-19	\$2,000.00	
2	Install 2 railings for steep entrance way.	31-Dec-19	\$1,680.00	
3	Purchase one HP "Van Accessible" sign for one of the current HP spots.	31-Dec-19	\$205.00	
4	Relocate the Raised Lettered Braille restroom signs and move them to the pull side wall.	31-Dec-19	\$120.00	
5	Repair crack in concrete walkway entrance.	31-Dec-19	\$1,190.00	
6	Install an accessible coat rack in Function Hall Coat Room.	31-Dec-19	\$150.00	
7	Make part of the bar accessible in the Function Hall.	31-Dec-19	\$1,127.00	
8	Replace the Men's and Women's Room Toilet with accessible ones.	31-Dec-19	\$2,090.00	
9	Install a curb cut for the sidewalk near the accessible entrance.	31-Dec-19	\$1,868.00	
10	Remove weeds from curb cut.	31-Dec-19	\$60.00	
11	Remove weeds from above ground HP Parking sign.	31-Dec-19	\$60.00	
12	Install a new crosswalk to provide accessible path of travel.	31-Dec-19	\$2,160.00	
13	Install a total of 3 curb cuts.	31-Dec-20	\$5,604.00	

**COST OF ADA TRANSITION PLAN  
for Department Head Review  
January 17, 2019**

<b>Item</b>	<b>Building/Item</b>	<b>Installation Deadline</b>	<b>Estimated Item Cost</b>	<b>Estimated Total Cost</b>
14	Install above ground HP parking signs and ground markings for the HP ground markings for the accessible parking on the golf course side of the Function Hall.	31-Dec-19	\$460.00	
15	Repaint the ground markings for the HP accessible parking space near the accessible entrance of the function hall.	31-Dec-19	\$930.00	
16	Relocate the restroom signs from the doors to the pull side of each door.	31-Dec-19	\$120.00	
17	Install accessible coat hooks in both the Men's and Women's restrooms and locker rooms.	31-Dec-19	\$296.00	
18	Lower the mirrors in both the Men's and Women's restroom to an accessible height.	31-Dec-19	\$240.00	
19	Lower the paper towel dispensers in both the Men's and Women's restrooms.	31-Dec-19	\$120.00	
20	Install accessible urinals in both the Men's restroom and locker room.	31-Dec-19	\$3,100.00	
21	Install a paddle handle on the doors connecting the Men's and Women's Restroom to the parlor.	31-Dec-19	\$152.00	
22	Install accessible handles on both office doors.	31-Dec-19	\$152.00	
23	Purchase & install a pool lift for the pool area.	31-Dec-21	\$2,995.00	
24	Lower the soap dispensers in both the Men's and Women's locker rooms.	31-Dec-19	\$120.00	
25	Install accessible handles on the accessible stalls in both the Men's and Women's locker rooms.	31-Dec-19	\$184.00	
26	Install accessible lockers in both the Men's and Women's locker rooms.	31-Dec-19	\$436.00	

**COST OF ADA TRANSITION PLAN  
for Department Head Review  
January 17, 2019**

<b>Item</b>	<b>Building/Item</b>	<b>Installation Deadline</b>	<b>Estimated Item Cost</b>	<b>Estimated Total Cost</b>
27	Post sign(s) informing people with disabilities of the accessible path to access the Men's and Women's locker rooms.	31-Dec-19	\$500.00	
28	Install accessible showers in both the Men's and Women's locker rooms.	31-Dec-19	\$4,800.00	
29	Install an HP accessible parking space in the parking lot between the locker rooms and the Pub.	31-Dec-19	\$205.00	
30	Tighten the stall lock on the accessible stall in the Men's Restroom.	31-Dec-19	\$325.00	
31	Publicize the availability of golf carts to access the pool area as an ADA reasonable accommodation.	31-Dec-19	\$0.00	
32	Install another railing on the steps that lead from the function hall to the pool.	31-Dec-19	\$380.00	
				<b>\$33,829.00</b>
	<b>GROTON ELECTRIC LIGHT DEPARTMENT</b>			
1	Install a HP "Van Accessible" parking sign at the HP accessible parking space.	31-Dec-19	\$205.00	
2	Install accessible coat hooks in both the Men's and Women's restrooms.	31-Dec-19	\$130.00	
3	Install accessible coat hooks in both the Men's and Women's restrooms.	31-Dec-19	\$815.00	
4	Install an A/V alarm in the small conference room.	31-Dec-19	\$1,560.00	
5	Install knurled handles on the Janitor and Storage closets.	31-Dec-19	\$310.00	
				<b>\$3,020.00</b>

**COST OF ADA TRANSITION PLAN**  
**for Department Head Review**  
**January 17, 2019**

Item	Building/Item	Installation Deadline	Estimated Item Cost	Estimated Total Cost
	<b>LEGION HALL</b>			
1	Repave the area where the current HP accessible parking space is located.	30-Jun-19	\$3,380.00	
2	Stripe the current HP accessible parking space.	30-Jun-19	\$1,340.00	
3	Add a "Van Accessible" space where the current HP accessible space is located.	31-Dec-19	\$205.00	
4	Remove the lip from the walkway to the accessible entrance.	31-Dec-19	\$480.00	
5	Repair the cracks on the walkway to the accessible entrance.	31-Dec-19	\$720.00	
6	Post a directional sign for people with disabilities to the accessible entrance.	31-Dec-19	\$85.00	
7	Relocate the items being stored in the hallway at the accessible entrance.	31-Dec-19	\$120.00	
8	Designate the Women's restroom as the accessible restroom.	31-Dec-19	\$145.00	
				<b>\$6,475.00</b>
	<b>LOST LAKE FIRE STATION</b>			
1	Install one HP Van Accessible space with ground markings and above ground sign.	31-Dec-19	\$385.00	
2	Attach the loose Women's Room shower door to allow accessibility.	31-Dec-19	\$120.00	
3	Relocate the trash bin obstructing the accessible sink.	31-Dec-19	\$120.00	
4	Install two handrails on the walkway in front of building.	31-Dec-19	\$760.00	
5	Repair the cracks and holes on the sidewalk in the rear of Lost Lake Fire Station.	31-Dec-18	\$480.00	

**COST OF ADA TRANSITION PLAN  
for Department Head Review  
January 17, 2019**

Item	Building/Item	Installation Deadline	Estimated Item Cost	Estimated Total Cost
6	Purchase an International Symbol of Access sign for the currently designated HP accessible parking space.	31-Dec-19	\$205.00	
7	Repaint the crosswalk ground markings.	31-Dec-19	\$2,160.00	
8	Repaint the HP accessible parking space ground markings.	31-Dec-19	\$730.00	
9	Install knurled handles on both room A109 and A117 doors which are custodians, and storage closets.	31-Dec-19	\$430.00	
				<b>\$5,390.00</b>
	<b>POLICE STATION</b>			
1	Install an A/V alarm in the unisex restroom and hallway near interview room.	31-Dec-19	\$1,560.00	
2	Insulate the pipe on the sink in the unisex restroom.	31-Dec-19	\$260.00	
3	Lower the tampon container in the unisex restroom.	31-Dec-19	\$120.00	
4	Lower the service counter in front of the Dispatch room.	31-Dec-19	\$3,140.00	
5	Relocate or install a new mat at the front entrance of the Groton Police Department.	31-Dec-19	\$115.00	
6	Install one "Van Accessible" sign on the pole at one of the HP spaces.	31-Dec-19	\$290.00	
				<b>\$5,485.00</b>
	<b>PRESCOTT SCHOOL</b>			
1	Relocate the accessible HP parking space near the ramp entrance to a space along the front side of the building with an above ground sign attached to a pole in the grass.	31-Dec-19	\$820.00	

**COST OF ADA TRANSITION PLAN  
for Department Head Review  
January 17, 2019**

<b>Item</b>	<b>Building/Item</b>	<b>Installation Deadline</b>	<b>Estimated Item Cost</b>	<b>Estimated Total Cost</b>
2	Add two new accessible parking spaces in the rear of the building and removing the accessible space currently in the rear	31-Dec-19	\$605.00	
3	Install one "Van Accessible" space provided at Prescott School.	31-Dec-19	\$230.00	
4	Remove "Reserved for Secretary" sign and purchase sign and mount it at the appropriate height at the accessible parking space on the side of the building.	31-Dec-19	\$0.00	
5	Make the Front Entrance and Ramp Entrance doors easier to open.	30-Jun-19	\$145.00	
6	Remove or replace the mat at the Ramp Entrance door that is a potential tripping hazard.	30-Jun-19	\$72.00	
7	Install a railing on the steps at the front entrance of Prescott School.	30-Jun-19	\$380.00	
8	Repair the large cracks in the ramp to the side entrance of the building.	30-Jun-19	\$595.00	
9	Smooth out the 1-inch lip located at the base of the ramp at the side entrance of the building.	30-Jun-19	\$960.00	
10	Excavate and regrade a 4-foot flat spot directly in front of the rear entrance of the building.	31-Dec-19	\$1,475.00	
11	Install new railings that are properly installed ¾ inches from the concrete wall on the basement entrance on the side of the building.	31-Dec-19	\$3,705.00	
12	Install a Directional sign informing people with disabilities how to access the basement.	31-Dec-19	\$85.00	
13	Install Raised Letter Braille Room Number signs in Prescott School.	31-Dec-19	\$1,190.00	

**COST OF ADA TRANSITION PLAN  
for Department Head Review  
January 17, 2019**

<b>Item</b>	<b>Building/Item</b>	<b>Installation Deadline</b>	<b>Estimated Item Cost</b>	<b>Estimated Total Cost</b>
14	Install knurled handles on the Electrical Room Door (Gym), Room B120, Room 216.	31-Dec-19	\$285.00	
15	Post ADA public notice at Prescott School.	31-Dec-19	\$0.00	
16	Install Fire Doors in the Gym.	31-Dec-19	\$1,120.00	
17	Remove the concreted debris and buckets of trash in the basement hallway in front of the Parent Resource Center.	31-Dec-19	\$435.00	
18	install an accessible counter in Room 309 (School Admin Office).	31-Dec-19	\$3,140.00	
19	install a door on the accessible stall in the B118 Women's Room.	31-Dec-19	\$240.00	
20	Install accessible coat hooks in the both Men's and Women's basement restrooms.	31-Dec-19	\$130.00	
21	Relocate the desk blocking an accessible path to the accessible stall in the B118 Women's Restroom.	31-Dec-19	\$290.00	
22	Install hardware on every stall door in the Prescott School restrooms.	31-Dec-19	\$570.00	
23	Install a full elevator to provide access to all floors in order to facilitate the programming planned at Prescott School.	30-Jun-20	\$150,000.00	
	<b>GRANT APPLICATION</b>			<b>\$166,472.00</b>
	<b>PUBLIC LIBRARY</b>			
1	Install an accessible coat hook in the Men's and Women's 3 <sup>rd</sup> Floor Restrooms and the 1 <sup>st</sup> Floor Family Restroom.	31-Dec-19	\$95.00	
2	Install insulation on the sinks in every restroom.	31-Dec-19	\$360.00	
3	Install a knurled handled on the 3 <sup>rd</sup> Floor "Roof Access" door and the 2 <sup>nd</sup> Floor "Sprinkler Room" door.	31-Dec-19	\$290.00	

**COST OF ADA TRANSITION PLAN  
for Department Head Review  
January 17, 2019**

Item	Building/Item	Installation Deadline	Estimated Item Cost	Estimated Total Cost
4	Remove bookcases in the 2 <sup>nd</sup> Floor Women's and Staff restrooms.	31-Dec-19	\$60.00	
5	Install Elevator Hall call buttons with Raised and Braille lettering.	31-Dec-19	<b>\$310.00</b>	
6	Install an accessible sink in the 1 <sup>st</sup> Floor Community Room.	31-Dec-19	\$1,600.00	
7	Raise the HP Signs to the correct height.	31-Dec-19	<b>\$120.00</b>	
8	Purchase one HP "Van Accessible" sign for one of the current HP spots.	31-Dec-19	<b>\$205.00</b>	
9	Repair or patch curb cut to sidewalk leading to Library accessible entrance.	31-Dec-19	\$1,200.00	
10	Install truncated domes on parking lot curb cut once repaired or patched.	31-Dec-19	\$190.00	
	<b>TOWN HALL</b>			
1	Install insulation on the sinks in both the Men's and Women's Restrooms.	31-Dec-19	\$120.00	
2	Remove shelf from Women's Room preventing a 5ft. turning radius	31-Dec-19	\$60.00	
3	Remove wires causing a tripping hazard in 2 <sup>nd</sup> Floor Conference Room and 1 <sup>st</sup> Floor meeting room.	31-Dec-19	\$240.00	
4	Install an accessible coat rack in the 1st Floor Stairway and 2 <sup>nd</sup> Floor Conference Room.	31-Dec-19	\$980.00	
5	Install a middle railing on the front entrance stairs.	31-Dec-19	\$3,600.00	
6	Remove the "Employees Only" and to install an appropriate raised and lettered sign on the wall next to that entrance.	31-Dec-19	\$205.00	
7	Raise the height of the HP parking signs.	31-Dec-19	\$360.00	

**COST OF ADA TRANSITION PLAN  
for Department Head Review  
January 17, 2019**

<b>Item</b>	<b>Building/Item</b>	<b>Installation Deadline</b>	<b>Estimated Item Cost</b>	<b>Estimated Total Cost</b>
8	Move the 2 <sup>nd</sup> HP parking spot away from failing snow and debris and with less slope.	31-Dec-19	\$480.00	
9	Repair cracks on ramps that exceeds ¾ inches.	31-Dec-19	\$680.00	
10	Repaint railings on the ramp as well as the steps.	31-Dec-19	\$1,280.00	
11	Acquire Sorensen type video relay service to enhance the Town's communication access.	31-Dec-19	\$0.00	
				<b>\$8,005.00</b>
	<b>TRANSFER STATION</b>			
1	Install an "Employee Only" sign at the Transfer Station office.	31-Dec-19	\$145.00	
2	Install one HP parking plus one "Van Accessible" sign on 2 poles outside the office entrance.	31-Dec-19	\$290.00	
3	Provide an access ramp to the station office.	31-Dec-21	\$7,640.00	
				<b>\$8,075.00</b>
	<b>TOTAL SUM OF ALL PLANS</b>			<b>\$236,883.00</b>