



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432
Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR RECREATIONAL WATER

Legend

DATE PRINTED: 07/06/2023
CLIENT NAME: Nashoba Assoc. Boards of Health
CLIENT ADDRESS: 30 Central Avenue
Ayer, MA 01432

SAMPLE ID #: 2307-00130-001
SAMPLED BY: Olejarz, Cara-NABH

LOCATION: Town Beach Groton, Sargisson

Passes ✓
Fails EPA Primary ⊗
Fails EPA Secondary ▼
Fails State Guideline ✕
Attention ▲

DATE AND TIME COLLECTED: 07/05/2023 09:40AM
DATE AND TIME RECEIVED: 07/05/2023 10:00AM
ANALYSIS PACKAGE: M-Beach
RECEIPT TEMPERATURE: NA
CLIENT JOB #: NABH# NA8766

MORE LOC INFO:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
E. coli MPN*	4	MPN/100mL	✓		1	235/100 mL	SM 9223B	MR-MA	07/06/2023 08:47AM
Total Coliform / E.coli Bacteria Preparation (Colilert®-18 Quanti-Tray®) 20th ED SM 9223B MR-MA 07/05/2023 12:06PM									



Erin Shaw

Erin Shaw
Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432
Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR RECREATIONAL WATER

Legend

DATE PRINTED: 07/06/2023
CLIENT NAME: Nashoba Assoc. Boards of Health
CLIENT ADDRESS: 30 Central Avenue
Ayer, MA 01432

Passes ✓
Fails EPA Primary ⊗
Fails EPA Secondary ▽
Fails State Guideline ×
Attention ▲

SAMPLE ID #: 2307-00134-001
SAMPLED BY: Olejarz,Cara-NABH
LOCATION: Baby Beach Groton

DATE AND TIME COLLECTED: 07/05/2023 05:22AM
DATE AND TIME RECEIVED: 07/05/2023 10:00AM
ANALYSIS PACKAGE: M-Beach
RECEIPT TEMPERATURE: NA
CLIENT JOB #: NABH# NA8767

MORE LOC INFO:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
E. coli MPN*	27	MPN/100mL	✓		1	235/100 mL	SM 9223B	MR-MA	07/06/2023 08:47AM
Total Coliform / E.coli Bacteria Preparation (Colilert®-18 Quanti-Tray®) 20th ED							SM 9223B	MR-MA	07/05/2023 12:06PM



Erin Shaw

Erin Shaw
Laboratory Director