

COMMONWEALTH OF MASSACHUSETTS
Groton, Massachusetts

	Percolation Test	Percolation Test
Date: 4/27/04	P-1	P-2
Observation Hole #	TH-1 & TH-2	TH-3 & TH-5
Depth of Perc	36"	36"
Start Pre-Soak		
End of Pre-soak		
Table at 12"		
Time at 9"	24 Gal's.	24 Gal's.
Time at 6"	< 15 Min.	< 15 Min.
Time (9"-6")		
Rate Min./Inch	2	2

Site Passed

Site Failed

Performed By: J. Hannaford - Norse Design Services, Inc.

Witnessed By: B. Braley - Groton Board of Health

Comments: _____

COMMONWEALTH OF MASSACHUSETTS
Groton, Massachusetts

	Percolation Test	Percolation Test
Date: 4/27/04	P-3	P-4
Observation Hole #	TH-4 & TH-6	TH-7 & TH-8
Depth of Perc	36"	30"
Start Pre-Soak		
End of Pre-soak		
Table at 12"		
Time at 9"	24 Gal's.	24 Gal's.
Time at 6"	< 15 Min.	< 15 Min.
Time (9"-6")		
Rate Min./Inch	2	2

Site Passed

Site Failed

Performed By: J. Hannaford - Norse Design Services, Inc.

Witnessed By: B. Braley - Groton Board of Health

Comments: _____

COMMONWEALTH OF MASSACHUSETTS
Groton, Massachusetts

	Percolation Test	Percolation Test
Date: 4/27/04	P-5	P-6
Observation Hole #	TH-9	TH-11
Depth of Perc	36"	48"
Start Pre-Soak		
End of Pre-soak		
Table at 12"		
Time at 9"	24 Gal's.	24 Gal's.
Time at 6"	< 15 Min.	< 15 Min.
Time (9"-6")		
Rate Min./Inch	2	2

Site Passed

Site Failed

Performed By: J. Hannaford - Norse Design Services, Inc.

Witnessed By: B. Braley - Groton Board of Health

Comments: _____

COMMONWEALTH OF MASSACHUSETTS
Groton, Massachusetts

	Percolation Test	Percolation Test
Date: 4/27/04	P-7	P-8
Observation Hole #	TH-13	TH-14
Depth of Perc	36"	48"
Start Pre-Soak		
End of Pre-soak		
Table at 12"		
Time at 9"	24 Gal's.	24 Gal's.
Time at 6"	< 15 Min.	< 15 Min.
Time (9"-6")		
Rate Min./Inch	2	2

Site Passed

Site Failed

Performed By: J. Hannaford - Norse Design Services, Inc.

Witnessed By: B. Braley - Groton Board of Health

Comments: _____

COMMONWEALTH OF MASSACHUSETTS
Groton, Massachusetts

	Percolation Test	Percolation Test
Date: 4/27/04	P-9	P-10
Observation Hole #	TH-12	TH-10
Depth of Perc	36"	24"
Start Pre-Soak		
End of Pre-soak		
Table at 12"		
Time at 9"	24 Gal's.	24 Gal's.
Time at 6"	< 15 Min.	< 15 Min.
Time (9"-6")		
Rate Min./Inch	2	2

Site Passed

Site Failed

Performed By: J. Hannaford - Norse Design Services, Inc.

Witnessed By: B. Braley - Groton Board of Health

Comments: _____